

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7135-0785:109 Page 1 of 1

CATEGORY: Audible Devices

LISTEE: Wheelock Inc., 273 Branchport Ave., Long Branch, NJ 07740
Contact: Luy Nguyen (732) 222-6880 Fax (732) 222-5607

DESIGN: Models CH-BF1, CH-BF2, CH-CF1, CH-CF2, CH-DF1, CH-DF2, CH70-24 and CH-90-24 chimes.

Models CH-BF1, CH-BF2, CH-CF1, CH-CF2, CH-DF1, CH-DF2 chime/strobes followed by suffix -W, -R, -B, -A, -G (color), followed by -S (15cd), -H (15cd), or -M (117cd), followed by -12 or -24 (voltage).

Models CH-CF1, CH-DF1 synchronized chime strobes, followed by -SL (15cd), -SLM (15/75cd) or -SHPW (110cd).

All units may be followed by additional suffixes to designate lens orientation, lens lettering and plate color. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: BF2, CF2, DF2: 9-15.6 VDC
BF1, CF1, DF1: 18-31 VDC
CH70-24, CH90-24: 20-31 VDC

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. For synchronized strobes, Models SM-SCM-24 sync control module must be used.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as audible and audible/visual devices for use with separately listed compatible fire alarm control units. For private mode and indoor use only. If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

*Rev. 1-21-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 16, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager